



January 5, 2018

Mr. Kyle Manning, P.E.  
Senior Project Manager  
Durham County Engineering and Environmental Services  
5926 Highway 55 East  
Durham, North Carolina 27713

**Re: Change Order Request  
Triangle WWTP Aeration System Improvements  
Durham County Reference No. 1700000832**

Dear Mr. Manning:

Pursuant to your request, Black and Veatch understands that Durham County is requesting that the two 125 horsepower positive displacement blowers proposed for the aeration system improvements be configured to operate automatically using the plant's existing dissolved oxygen control system. This is a change from the original scope and will require additional engineering effort associated with updates to the contract documents and coordination with the County's system integrator, CITI. We are therefore requesting additional compensation in the amount of \$17,000 to incorporate this change. This change is not expected to impact the current schedule.

Please confirm this change request is acceptable to the County. If you have any questions, please do not hesitate to contact me at (919) 463-3047 or [brinkleyjw@bv.com](mailto:brinkleyjw@bv.com)

Very truly yours,

**BLACK & VEATCH INTERNATIONAL COMPANY**

  
John Brinkley, P.E., BCEE, D.WRE  
Project Manager