

FY26 Animal Shelter Repairs/Services:

Completed-

- Underpinned foundation near dog hold kennels- block wall was showing cracks in the joints and it was determined that the foundation was sagging.
- Replaced backup generator (Also serves DCo Sheriff's Animal Services Bldg)- generator stopped working and repair parts were not able to be found.
- Repaired and sealed parking lots- this was scheduled within our CIP program for parking lots
- Repairs based on State inspections (door/door frame repairs, electrical outlet covers, kennel surfaces sealed/painted)- made repairs as noted in Dept of Agriculture inspection report
- Replaced lights in surgical suite- it was requested to have the lighting brighter in the surgical suite
- Replaced HVAC Package unit for cat kennel area.
- Replaced hot water heaters, waiting on inspection
- Installed dishwasher(s) in break room and vet room- waiting on inspection
- Repair hose bibb connections

Ongoing-

- HVAC unit replacement for dog hold kennel area- We received a proposal through Omnia (a cooperative agreement contract source), we are waiting for contract processing to open back up. The unit provides cooling, it will not provide heat.
- HVAC fire/smoke damper inspection and repairs- inspection was completed on January 9, 2026. One damper needs to be replaced due to being installed in the wrong direction.- We received a repair quote, but initial contractor and DCo legal will not agree to terms and conditions, so soliciting a new contractor for repair.
- Replace lighting as needed.

FY25 Animal Shelter Repairs/Services:

Completed-

- Replaced all internal components on the incinerator