



## PURCHASING DIVISION

**TO: All Proposers**

**DATE: 2/14/2025**

## PURCHASING DIVISION

### ADDENDUM NO. 1

#### **Generator for Northern Convenience Site (IFB No. 25-013R2)**

This **ADDENDUM No. 1** forms part of Durham County's Request for Proposals (**IFB No. 25-013R2**) – **Generator for Northern Convenience Site**. All other requirements of the original Scope of Services remain in effect in their respective order. Receipt of this Addendum must be acknowledged on the Addendum Acknowledgement Form included in the RFP document.

1. The due date for receiving proposals for IFB No. 25-013R2 has been **changed** to March 13, 2025, at 2:00 P.M., Eastern Time.
2. A Non-Mandatory Site Visit was held on January 29, 2025, at 10:00 A.M., Eastern Time. The list of attendees is attached.
3. **The last day for receiving questions regarding this project was February 12, 2025 at 3:00 P.M., Eastern Time.** Attached are the questions received along with the responses provided by the Project Manager.

Should you have any questions regarding this Addendum, please contact Jonathan Hawley, Procurement Manager, at 919-560-0056.

Sincerely,

*Jonathan Hawley*

Procurement Manager

919-560-0056

919-560-0041

[purchasinggroup@dconc.gov](mailto:purchasinggroup@dconc.gov)

Durham County Administration Building II • 201 E. Main Street, 7th Floor • Durham, NC 27701  
(919) 560-0051 • Fax (919) 560-0057 • [www.dconc.gov](http://www.dconc.gov)  
Equal Employment /Affirmative Action Employer

## **Questions and Answers**

### **Generator for Northern Convenience Site (IFB No. 25-013R2)**

#### **ADDENDUM NO. 1**

**1. Question: What Generator Manufacturer's did HDR contact?**

**Answer:** We reached out to Caterpillar, Cummings and Koehler for potential contractors that could complete this work. The technical specifications include the acceptable manufacturers, and it was noted that Generac would not be an acceptable supplier.

**2. Question: Is traffic coordination needed for setting the generator?**

**Answer:** It was stated that the generator is installed on the compactor and commercial hauling road and the work will not interfere with residential customer traffic. With some advance notice the County can coordinate with their haulers to exit the site in the opposite direction in order to avoid conflicts with a crane or equipment setting the generator. Otherwise the work area should still accommodate the limited commercial traffic at the site.

**PRE-BID SITE VISIT – 10:00 AM January 29, 2025**

[illegible]