



**COUNTY OF DURHAM
PURCHASING DIVISION**

To: Wendell M. Davis, County Manager

From: Jacqueline Boyce, C.P.M., CLGPO
Procurement Manager



Date: March 26, 2018

Re: IFB 18-001Rebid2 – Influent Pump Station Back-Up Power Modifications

I am hereby requesting your approval for rejection of the lowest bid received under IFB 18-001Rebid2 on March 20, 2018 at 2:00 P.M. The Invitation for Bids was advertised on March 8, 2018. We received bids from two (2) companies. Attached is a copy of the Bid Tabulation.


The lowest bid submitted by JL Britt Electric, Inc., is deemed non-responsive due to failure to provide reasonable documentation demonstrating that good faith efforts were made in meeting our MWBE requirements. By Statute (GS 143-128.2 and GS 143-131), failure to provide documentation to demonstrate that a bidder made the required good faith efforts is grounds for rejection of the bid. Therefore, it is our recommendation that JL Britt Electric, Inc.'s bid be deemed non-responsive, and we request your approval to award the contract to the next lowest bidder.

The next lowest bidder, MV Electric, LLC, is an MWBE Certified Woman-Owned business and will also be utilizing subcontractors with a total of 6% MWBE Certified Black-American business and 5% MWBE Certified Woman-Owned business.

If you approve the aforementioned request, please indicate so by checking the appropriate line and then signing below.

 X Approve rejection of the lowest bid and award contract to the next lowest bid received under IFB 18-001Rebid2.

DocuSigned by:



Wendell M. Davis, County Manager

3/27/2018


Date

cc: Kyle Manning, Project Manager
Purchasing Bid Files

IFB 18-001Rebid2**Influent Pump Station Back-Up Power Modifications
Bid Tabulation**

Company Name	JL Britt Electric, Inc.	MV Electric, LLC
License #	4648-U, 74783	U-04364
Bid Form	Yes	Yes
Non Collusion Affidavit	Yes	Yes
Bid Deposit		
- Bid Bond w/Power of Attorney	Yes	Yes
M/WBE Appendices	Yes	Yes
Vendor Application/W-9 Form	No	Yes
Affidavit of Compliance/E-Verify	Yes	Yes
Total Base Bid Price	\$676,124.00	\$739,500.00

I certify that the above is a true and accurate tabulation of the bids received and opened at 2:00 P.M., on March 20, 2018.



McKim & Creed


Signature:


[Signature] 3/20/18

CERTIFIED DETAILED BID TABULATION
INFLUENT PUMP STATION BACK-UP POWER MODIFICATIONS
DURHAM COUNTY
IFB 18-001 REBID2
M&C PROJECT NO. 01471-0011
BID DATE: MARCH 20, 2018

Item	Description	Quantity	Unit	JL Britt Electric, Inc.		MV Electric, LLC	
				Unit Price	Total Cost	Unit Price	Total Cost
1	Mobilization	1	LS	\$5,000.00	\$5,000.00	\$36,000.00	\$36,000.00
2	Cable/Conduit Installation	1	LS	\$237,774.00	\$237,774.00	\$349,000.00	\$349,000.00
3	Variable Frequency Drive Installation	1	LS	\$251,771.00	\$251,771.00	\$275,000.00	\$275,000.00
4	Circuit Breaker Replacement	1	LS	\$167,879.00	\$167,879.00	\$50,000.00	\$50,000.00
5	Arc-Flash Calculations/Labeling	1	LS	\$5,500.00	\$5,500.00	\$5,500.00	\$5,500.00
6	New 800A Breaker Replacement	1	Allowance	\$200.00	\$200.00	\$9,000.00	\$9,000.00
7	Contingency for Repairing (1) Damaged Ductbank Conduit	1	Allowance	\$5,000.00	\$5,000.00	\$10,000.00	\$10,000.00
8	Testing/Project Close-Out	1	LS	\$3,000.00	\$3,000.00	\$5,000.00	\$5,000.00
					\$676,124.00		\$739,500.00

Certified as Correct




 K. Jason Savage, PE
 Construction Administrator
 McKim & Creed, Inc.

Date

3/20/18