



Legislation Details (With Text)

File #: 18-1045 **Version:** 1 **Name:**

Type: Action Item **Status:** Consent Agenda

File created: 9/18/2018 **In control:** Board of County Commissioners

On agenda: 10/8/2018 **Final action:**

Title: Amendment of Xylem d/b/a Godwin Pumps Services Contract in the Amount of \$123,500 for a Total Contract Value of \$153,500 for Emergency Pumping Services at the Stirrup Iron Creek Lift Station

Sponsors:

Indexes:

Code sections:

Attachments: 1. Submersible Rental Quote - Xylem, 2. Supplement Form - Xylem Emergency Pumping, 3.

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

Item:

Amendment of Xylem d/b/a Godwin Pumps Services Contract in the Amount of \$123,500 for a Total Contract Value of \$153,500 for Emergency Pumping Services at the Stirrup Iron Creek Lift Station

Date Of BOCC Meeting: October 8, 2018

Request For Board Action:

The Board is requested to approve an amendment to the existing Xylem d/b/a Godwin Pumps services contract in the amount of \$123,500 for a total contract value of \$153,500 to continue to provide emergency pumping services at the Stirrup Iron Creek Lift Station and to authorize the County Manager to execute the amendment with Xylem d/b/a Godwin Pumps.

Xylem is providing emergency pumping services at the Stirrup Iron Creek Lift Station until the completion of the Stirrup Iron Creek Lift Station Capacity Improvements (IFB 18-029R1) project due to the permanent failure of one 200 HP wastewater pump.

Alignment With Strategic Plan: This action is in accordance with Durham County Strategic Plan Goal 4: “Environmental Stewardship and Community Prosperity,” as this project will continue to minimize the risk for a sanitary sewer overflow at the Stirrup Iron Creek Lift Station due to insufficient pumping capacity. Additionally, this action will allow Durham County to stay in compliance with the County’s Collection System Permit and DEQ regulations.

Resource Persons:

Peri Manns ASLA, Interim General Manager; Stephanie Brixey, Deputy Director of Engineering and Environmental Services and Kyle Manning PE, Senior Project Manager

County Manager’s Recommendation:

The County Manager recommends the Board approve the amendment to the existing Xylem d/b/a Godwin Pumps services contract in the amount of \$123,500 for a total contract value of \$153,500 to continue to provide emergency pumping services at the Stirrup Iron Creek Lift Station and to authorize the County Manager to

execute the amendment with Xylem d/b/a Godwin Pumps.

County Manager: _____